



Certificate of Compliance

Certificate Number: LR 23701-73

Revision: LR 23701-100

Date Issued: February 9, 1994

Issued To: ENTRELEC INC.
9-R, Place Du Commerce
Brossard, Québec
J4W 2V6

The products listed below are eligible to bear the CSA Mark.

Issued By: J.P. Boivin, Eng.
Montreal, PQ, CANADA

Signature

PRODUCTS

Terminal blocks, recess-type, disconnect rail mounted, triple-deck, Series D2.5/6D, rated 300V, 20A, (24V dc for LED circuit), for use with solid or stranded copper Nos 22 to 14 AWG flexible wire.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 158-1987 - Terminal Blocks

/cor3t1m



Product Certification History

Certificate Number: LR 23701-73

Revision: LR 23701-100

Date Issued: February 9, 1994

Revision	Date	Issued By	Description
LR 23701-100	Feb. 9/94	J.P. Boivin	Increase of range to 22-14AWG

/cor3t1m