



Certificate of Compliance

Certificate: 1342774 (LR 23701)

Master Contract: 161378

Project: 2481121

Date Issued: February 29, 2012

Issued to: ABB France

Activite Raccordement, BP 114
10 rue Amperes
Chassieu Cedex, 69685
France
Attention: Laurence Pionchon

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Pierre-Luc Avoine

Issued by: Pierre-Luc Avoine, Eng.

PRODUCTS

CLASS 6228 81 - WIRE CONNECTING DEVICES - Terminal Assemblies - Certified to US Standards

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal Blocks, single block, rail type, Cat Nos. (models maybe followed by VO, or 1, or 2, or 3, or 4, or 4A.VO, or 23, or T or TA).

Cat. No	Voltage Rating	Spacing Group	Wire Range	Current Rating	Tight Torque	Applicable Notes
MA2.5/5.SNB	600	B,C,D,E	28-12AWG	15	0.5-0.8Nm	
M4/6.D2.SNBT	600	B,C,D,E	24-10 AWG	15	0.5-0.8Nm	
M4/6.SB	600	B,C,D,E	24-10AWG	15	0.5-0.8Nm	
M4/6.SN	600	B,C,D,E	24-10 AWG	15	0.5-0.8Nm	
M4/6.SNB	600	B,C,D,E	24-10 AWG	15	0.5-0.8Nm	
M4/6.SNBT	600	D,E	24-10 AWG	15	0.5-0.8Nm	
M4/6.SNTS	600	B,C,D,E	24-10 AWG	15	0.5-0.8Nm	



Certificate: 1342774 (LR 23701)

Master Contract: 161378

Project: 2481121

Date Issued: February 29, 2012

M6/8.SB	600	B,C,D,E	22-8 AWG	20	0.8-1.0Nm	
M6/8.SNB	600	B,C,D,E	22-8AWG	20	0.8-1.0Nm	
M6/8.SN	600	B,C,D,E	22-8AWG	20	0.8-1.0Nm	

Notes:

1. The terminal blocks are certified as components for use in certified equipment where the acceptability of the combination is to be determined by CSA.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 158-10 - Terminal Blocks
ANSI/UL 1059 (4th Ed.) - Electrical Terminal Blocks