



Ref. Certif. No.

FR_709272

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Power supply
Power Supply „Zero Cabinet“

Name and address of the applicant

PULS GmbH
Elektrastr. 6
81925 München - Germany

Name and address of the manufacturer

PULS GmbH
Elektrastr. 6
81925 München - Germany

Name and address of the factory

PULS INVESTICNI SRO
Prazska 5639
430 01 Chomutov - Czech Republic

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

PULS

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

FPT300.246-042-101, FPT300.242-002-101,
FPT300.242-008-102, FPT500.245-034-105,
FPT500.245-018-103, FPT500.241-002-101,
FPT500.241-006-104, FPT500.241-012-103

Additional information (if necessary may also be reported on page 2)

/

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 62368-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

20TH0250-62368-1_0

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.frSignature: **Jérôme RYSSON**
Certification Officer

Date: 10/08/2020

ANNEX

References, ratings and main characteristics:**FPT300.246-042-101:**

Input:

3 x 380-480 V; 0,52-0,43 A; 50-60 Hz

Output:

4 x 24-28 Vdc; max. 3,9 - 3,4 A

Total output power:

300 W (at +55 °C)

150 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

FPT300.242-002-101, FPT300.242-008-102:

Input:

3 x 380-480 V; 0,52-0,43 A; 50-60 Hz

Output:

24 Vdc; 300 W (below +55 °C)

24 Vdc; 150 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

FPT500.245-034-105:

Input:

3 x 380-480 V; 1,1-0,9 A; 50-60 Hz

Output:

4 x 24-28 Vdc; max. 12 A

Total output power:

600 W (below +45 °C)

500 W (at +55 °C)

350 W (at +70 °C)

Derate linearly between +45 °C and +70 °C

FPT500.245-018-103:

Input:

3 x 380-480 V; 1,1-0,9 A; 50-60 Hz

Output:

4 x 24-28 V; max. 9 A

Total output power:

600 W (below +45 °C)

500 W (at +55 °C)

350 W (at +70 °C)

Derate linearly between +45 °C and +70 °C

FPT500.241-002-101, FPT500.241-006-104, FPT500.241-012-103:

Input:

3 x 380-480 V; 1,1-0,9 A; 50-60 Hz

Output: 24-28 Vdc; 600W (below +45 °C)

24-28 Vdc; 500W (below +55 °C)

24-28 Vdc; 350W (at +70 °C)

Derate linearly between +45 °C and +70 °C



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 10/08/2020

Signature:  **Jérôme REYSSON**
Certification Officer

